



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 08/19/2026
Received: 07/24/2026
Sampled By:
Work Order: 6205006

**C
L
I
E
N
T** **Riverbend-Riverbank WD**

Attn: Lynn Van Zandt
461 SW Hebb Park Rd
West Linn OR, 97068
Phone: (971) 207-5147

Project:

Project # : N/A
PWSID # : 4100458

Sampling Location:

Lab Number

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
6205006-01	Sample Name: #1 31204 SW Riverlane Sampled: 7/24/26 9:00						Matrix: Drinking Water
Metals (Total)							
A Copper	1022	EPA 200.8	mg/L	0.0217	0.00102	1.3	08/14/26 21:24
A Lead	1030	EPA 200.8	mg/L	ND	0.00102	0.015	08/14/26 21:24
6205006-02	Sample Name: #2 466 Riverbend Sampled: 7/24/26 8:20						Matrix: Drinking Water
Metals (Total)							
A Copper	1022	EPA 200.8	mg/L	0.0908	0.00102	1.3	08/14/26 21:26
A Lead	1030	EPA 200.8	mg/L	0.00771	0.00102	0.015	08/14/26 21:26
6205006-03	Sample Name: #3 31705 SW Riverlane Sampled: 7/24/26 10:00						Matrix: Drinking Water
Metals (Total)							
A Copper	1022	EPA 200.8	mg/L	0.0931	0.00102	1.3	08/14/26 21:29
A Lead	1030	EPA 200.8	mg/L	ND	0.00102	0.015	08/14/26 21:29
6205006-04	Sample Name: #4 30920 SW Riverland Sampled: 7/24/26 8:37						Matrix: Drinking Water
Metals (Total)							
A Copper	1022	EPA 200.8	mg/L	0.658	0.00510	1.3	08/17/26 19:40
A Lead	1030	EPA 200.8	mg/L	0.00180	0.00102	0.015	08/14/26 21:32
6205006-05	Sample Name: #5 448 SW Hebb Park Road Sampled: 7/24/26 10:15						Matrix: Drinking Water
Metals (Total)							
A Copper	1022	EPA 200.8	mg/L	0.0327	0.00102	1.3	08/14/26 21:35
A Lead	1030	EPA 200.8	mg/L	ND	0.00102	0.015	08/14/26 21:35

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director