

RRWD Annual Meeting – System Operator Report – January 8, 2026

Chemical Testing – All testing is current, has passed inspection and reported to State

- Chlorine readings are recorded daily. Chlorine range is maintained at 0.30 to 0.75 ppm.
- Coliform Bacteria & eColi test is done monthly by Alexin Labs – retests are required after system repairs.
- Results have been posted to <http://www.rrwd.org/2025ChemicalTesting.pdf>
- Sampling Schedule has been posted to http://www.rrwd.org/2025ChemicalTesting_schedule.pdf

Monthly Flushing & Testing

- On flush day, generator & electronics are tested, filters are changed and water use is recorded.

Annual Water Use Reporting – reported to State

- Monthly usage is recorded and reported annually for year ending Sept 30. Yearly water use report has been posted to <http://www.rrwd.org/2025WaterUserReport.wrd.state.or.pdf>
- This year usage was 20,504 m gal, compared to 20-year average 21,818 m gal. Yearly water use graph has been posted to <http://www.rrwd.org/yearlywaterusegraph2006-2025.pdf>
- We continue to operate within our water right, and always get good cooperation from our neighbors when at times we need to reduce the usage in July-August.

Consumer Confidence Report – reported to State

- Written, published & distributed to Water District members by July 1.
- The current full report has been posted to http://www.rrwd.org/25RRWD_CCR.pdf

Cross Connection/Backflow Device Testing – done annually in Sept, results reported to State

- 43 homes, 44 devices tested in 2025 by Bens Backflow at a continued rate of \$35/unit.
- All devices passed initial testing with 2 repairs required.
- On-line reporting is available through the Oregon Health Authority and has been posted to <http://www.rrwd.org/41-00458-Riverbend-Riverbank-WD-2025ASR.pdf>

Certifications, Oregon Health Authority

- Bob has been certified as Small Water System Operator in Oregon.

Well Static Level testing

- Next well measurement is planned for April 2026 to verify levels have recovered as expected.

System Status – Distribution & Metering

- Reservoir tank cleaning and inspection was completed July 26, 2025. Next service is due in 2026.
- New well pump installation completed August 20, 2025 – pumping 105 gallons per minute.
- New chlorine monitoring system installed December 15, 2025 – previous system was installed 2009.
- Backup generator in the pumphouse is due for maintenance check in 2026.

Maintenance & Projects

- Customer service leak identified January 17, 2025 at 470 Riverbend Dr (Campagna).
- System main line leak repaired on Riverbend Dr July 15, 2025.
- Reservoir roof vent removed/cleaned/replaced September 2025.
- Reservoir inlet building overgrowth cleared October 2025.
- Pumphouse roof replaced and pumphouse painted October 2025.
- System main line leak detected on Riverbend Dr December 2, repairs completed December 3, 2025.

Thank you, Bob – Certified System Operator